



Martin J. Walsh
Mayor

Boston Inspectional Services Department Building and Structures Division

1010 Massachusetts Avenue Boston, MA 02118 Telephone: (617) 635-5300

VIOLATION NOTICE

Sean Lydon
Inspector of Buildings

JOHN MORIATY AND ASSOCIATES
3 CHURCH STREET SUTIE 2
WINCHESTER, MA 01890

DATE FILED: 07/29/2019

INSPECTOR: Deon Chandool

VIOLATION NUMBER: **V455437**

Owner or in control of property located in the City of Boston at:

50 - 150 CAUSEWAY ST BOSTON, MA 02114

WARD: 03

The Commissioner of the City of Boston Inspectional Services Department and the Inspector of Buildings of the City of Boston have adjudged certain property owned or controlled by you to be in violation of the Massachusetts State Building Code, pursuant to M.G.L. c. 143 s. 1 et seq., and 780 CMR 118.0 et seq. (8th Ed.), as amended. Notice of said violation and order to abate same through the remedy and within the time prescribed below is hereby provided pursuant to 780 CMR 118.2.

780 CMR:	Description	Violation Remedy
3301.2	Storage and Placement-material	Storage of equipment or material unsafe to the public Remedy: Store equipment and or material safely or stop work forthwith
	Lifting cables (clockers) frail and broke on lifting Steel Beams off truck. (HUB on Causeway).	Inspect and certify all lifting cables by a qualified and competent person before commencing said work.

Failure to correct this Violation within **24 Hours** of service of this Notice will result in criminal prosecution and/or civil penalties and fines.

Inspector

Deon Chandool

For the Commissioner

Date Issued

7/29/19



Martin J. Walsh
Mayor

Boston Inspectional Services Department Building and Structures Division

1010 Massachusetts Avenue Boston, MA 02118 Telephone: (617) 635-5300

VIOLATION NOTICE

Sean Lydon
Inspector of Buildings

JOHN MORIATY AND ASSOCIATES
3 CHURCH STREET SUITE 2
WINCHESTER, MA 01890

DATE FILED: 07/29/2019

INSPECTOR: Deon Chandool

VIOLATION NUMBER: **V455445**

Owner or in control of property located in the City of Boston at:

50 - 150 CAUSEWAY ST BOSTON, MA 02114

WARD: **03**

The Commissioner of the City of Boston Inspectional Services Department and the Inspector of Buildings of the City of Boston have adjudged certain property owned or controlled by you to be in violation of the Massachusetts State Building Code, pursuant to M.G.L. c. 143 s. 1 et seq., and 780 CMR 118.0 et seq. (8th Ed.), as amended. Notice of said violation and order to abate same through the remedy and within the time prescribed below is hereby provided pursuant to 780 CMR 118.2.

780 CMR:	Description	Violation Remedy
116.1	Unsafe Structure Lifting cables frail and broke upon lifting Steel Beams off truck. (HUB on Causeway)	To remedy the condition: Inspect and Certify all lifting cables by a qualified and competent person before commencing said work. Follow protocol agreed to in meeting on 07/29/19.

Failure to correct this Violation within **24 Hours** of service of this Notice will result in criminal prosecution and/or civil penalties and fines.

Inspector

Deon Chandool

For the Commissioner

Date Issued

7/29/19